



MAYNARD ROAD CORPORATION

Maynard Road Corporation
22 Church Street
Meriden, CT 06451

Phone (203) 235-0157
Fax (203) 634-1971

Robert V. Cappelletti
Secretary



Scott T. Griffith
President
Carlos Ruiz
Vice President
Cornelius J. Ivers
Treasurer
Lawrence Kendzior
Director
Emely M. Varona
Director

ADDENDUM NO. 4

Please be advised that Maynard Road Corporation is releasing Addendum No. 4 for Hanover Place to provide response to RFI #2, as follows:

1. Q: There is no clear indication of what type of insulation is to be used on the GLYS&R. What is required?
A: Please provide an allowance for insulation that meets requirements.
2. Q: It seems all geothermal piping is to be HDPE outside as well as inside. Please verify.
A: Yes.
3. Q: On the ductwork insulation it calls for attic ductwork to have a thickness of 1 ½ inches with a D/O finish. Please clarify what a D.O. finish is.
A: This will be clarified under separate cover via an addendum.
4. Q: On testing and balancing it seems that only the air side is to be balanced and no water side is mentioned. Please verify.
A: The Geothermal system is handled by Owner.
5. Q: The Engineer Shows the geothermal field zone manifolds as 3 inch HDPE but shows 4 inch going to the air separator. Please clarify if its 3 inch or 4 inch.
A: 3 inch
6. Q: Drawing M5 shows a 1 ½ inch pipe going from Building A to Building B. Drawing SM1 shows 1 ¼ inch pipe going form Building A to Building B. Please clarify.
A: 1 ½ inch

Receipt of this Addendum No. 4 should be acknowledged below and submitted as part of bidder's proposal.

PRINTED NAME

SIGNATURE

DATE