



MAYNARD ROAD CORPORATION

Maynard Road Corporation
22 Church Street
Meriden, CT 06451

Phone (203) 235-0157
Fax (203) 634-1971

Robert V. Cappelletti
Secretary



Scott T. Griffith
President
Carlos Ruiz
Vice President
Cornelius J. Ivers
Treasurer
Lawrence Kendzior
Director
Emely M. Varona
Director

ADDENDUM NO. 8

Please be advised that Maynard Road Corporation is releasing Addendum No. 8 for Hanover Place to provide response to RFI #4, as follows:

1. Q: Addenda #4 Q&A #2 indicates a requirement for HDPE Geothermal piping to be used outside as well as inside. Is this a requirement for distribution from boiler room to the heat pumps as well?
A: Yes, however, we will consider an equivalent alternative (not PVC).
2. Q: Since HDPE piping adds significant costs to the project and there are many alternatives – will you look at cost savings to use other equivalent products?
A: Bidders may submit an equivalent alternative to the HDPE piping.

Receipt of this Addendum No. 8 should be acknowledged below and submitted as part of bidder's proposal.

PRINTED NAME

SIGNATURE

DATE